

Annual **Drinking Water Quality Report 2017**

**CENTRAL HAMPSHIRE PSD**

**18540 Northwestern Pike**

**Augusta, WV 26704**

**PWS# WV3301406 – Rt. 28**

**PWS# WV3301411 – Central Hampshire**

**PWS# WV3301412 – Green Springs**

**April 3, 2018**

### **Why am I receiving this report?**

In compliance with the Safe Drinking Water Act Amendments, the **Central Hampshire PSD** is providing its customers with this annual water quality report. This report explains where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. The information in this report shows the results of our monitoring for the period of January 1st to December 31st, 2017 or earlier if not on a yearly schedule.

If you have any questions concerning this report, you may contact **James Hoffman, General Manager, 304-496-8882**. If you have any further questions, comments or suggestions, please attend any of our regularly scheduled water board meetings held on the **1<sup>st</sup> Tuesday** of every month at **6:00 PM** in the **Central Hampshire PSD office, Rte. 50, Augusta, WV**.

### **Where does my water come from?**

Your drinking water is **purchased** from the City of Romney which uses **surface** water from the South Branch River.

Green Springs drinking water is **ground water** (under the influence of surface water) from a spring.

### **Source Water Assessment**

A Source Water Assessment was conducted by the West Virginia Bureau for Public Health (WVBPH). The intake that supplies drinking water to the **City of Romney** has a higher susceptibility to contamination, due to the sensitive nature of surface water supplies and the potential contaminant sources identified within the area. This does not mean that this intake will become contaminated only that conditions are such that the surface water could be impacted by a potential contaminant source. Future contamination may be avoided by implementing protective measures. The source water assessment report which contains more information is available for review or a copy will be provided to you at our office during business hours or from the WVBPH 304-558-2981.

The spring that supplies drinking water to the **Central Hampshire PSD (Green Springs)** has a higher susceptibility to contamination, due to the sensitive nature of the aquifer in which the drinking water spring is located and the existing potential contaminant sources identified within the area. This does not mean that the wellfield will become contaminated; only that conditions are such that the ground water could be impacted by a potential contaminant source. Future contamination may be avoided by implementing protective measures. The source water assessment report which contains more information is available for review or a copy will be provided to you at our office during business hours or from the WVBPH 304-558-2981.

## Why must water be treated?

All drinking water contains various amounts and kinds of contaminants. Federal and state regulations establish limits, controls, and treatment practices to minimize these contaminants and to reduce any subsequent health effects.

## Contaminants in Water

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits of contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The source of drinking water (both tap and bottled water) includes rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals, and, in some cases radioactive material and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

**Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

**Inorganic contaminants**, such as salts and metals, which can be naturally-occurring, or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, farming.

**Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

**Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

**Radioactive contaminants**, which can be naturally-occurring or the result of oil and gas production and mining activities.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

## Water Quality Data Table

Definitions of terms and abbreviations used in the table or report:

- **MCLG - Maximum Contaminant Level Goal**, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MCL - Maximum Contaminant Level**, or the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technique.
- **MRDLG - Maximum Residual Disinfectant Level Goal**, or the level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect benefits of use of disinfectants to control microbial contaminants.
- **MRDL - Maximum Residual Disinfectant Level**, or the highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of disinfectant is necessary to control microbial contaminants.
- **AL - Action Level**, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **TT –Treatment Technique**, or a required process intended to reduce the level of a contaminant in drinking water

Abbreviations that may be found in the table:

- **ppm** - parts per million or milligrams per liter
- **ppb** - parts per billion or micrograms per liter
- **NA** – not applicable
- **NE** - not established
- **NTU** –Nephelometric Turbidity Unit, used to measure cloudiness in water

The **City of Romney** and **Central Hampshire PSD** routinely monitor for contaminants in your drinking water according to federal and state laws. The tables below show the results of our monitoring for contaminants.

**Table of Test Results - Regulated Contaminants – City of Romney**

Contaminant	Violation Y/N	Level Detected	Unit of Measure	MCLG	MCL	Likely Source of Contamination
<b>Microbiological Contaminants</b>						
Turbidity	N	0.29 100% of monthly samples <0.3	NTU	0	TT	Soil runoff
<b>Inorganic Contaminants</b>						
Barium	N	0.0352	ppm	2	2	Discharge from drilling waste; erosion of natural deposits

Fluoride	N	0.94	ppm	4	4	Erosion of natural deposits; water additive that promotes strong teeth
Nitrate	N	0.35	ppm	10	10	Runoff from fertilizer use; leakage from septic tanks, sewage; erosion of natural deposits
<b>Volatile Organic Contaminants</b>						
Chlorine	N	Annual avg. 1.5 Range 0.4-2.4	ppm	4 MRDLG	4 MRDL	Water additive used to control microbes
Haloacetic acids (HAAC5)	N	Annual avg. 28.8 Range 12.3-39.1	ppb	NA	60	By-product of drinking water disinfection
Total trihalomethanes (TTHMs)	N	Annual avg. 25.0 Range 10.1-34.2	ppb	NA	80	By-product of drinking water chlorination

**Table of Test Results - Unregulated Contaminants**

Contaminant	Violation Y/N	Level Detected	Unit of Measure	MCLG	MCL	Likely Source of Contamination
Sodium	N	3.82	ppm	NE	20	Erosion of natural deposits
Sulfate	N	13.5	ppm	250	250	Erosion of natural deposits

**Table of Test Results - Regulated Contaminants – Central Hampshire PSD, PWSID #3301411**

Contaminant	Violation Y/N	Level Detected	Unit of Measure	MCLG	MCL	Likely Source of Contamination
<b>Volatile Organic Contaminants</b>						
Chlorine	N	Annual avg. 0.9 Range 0.4-2.5	ppm	4 MRDLG	4 MRDL	Water additive used to control microbes
Haloacetic acids (HAAC5)	N	Annual avg. 41.8 Range 23.8 – 55.7	ppb	NA	60	By-product of drinking water disinfection

Total trihalomethanes (TTHMs)	N	Annual avg. 41.8 Range 25.1 – 100.3	ppb	NA	80	By-product of drinking water chlorination
----------------------------------	---	--	-----	----	----	---

Some people who drink water containing trihalenthanes in excess of the MCL over many years may experience problems with their liver, kidneys, or nervous system and may have an increases risk of getting cancer.

**Table of Test Results - Regulated Contaminants – Central Hampshire PSD Rt. 28, PWSID #3301406**

Contaminant	Violation Y/N	Level Detected	Unit of Measure	MCLG	MCL	Likely Source of Contamination
<b>Volatile Organic Contaminants</b>						
Chlorine	N	Annual avg. 0.9 Range 0.4-2.4	ppm	4 MRDLG	4 MRDL	Water additive used to control microbes
Haloacetic acids (HAAC5)	N	Annual avg. 45.7 Range 23.8 – 55.7	ppb	NA	60	By-product of drinking water disinfection
Total trihalomethanes (TTHMs)	N	Annual avg. 23.2 Range 25.1 – 100.3	ppb	NA	80	By-product of drinking water disinfection

**Table of Test Results - Regulated Contaminants – Central Hampshire PSD, Green Springs PWSID #3301412**

Contaminant	Violation Y/N	Level Detected	Unit of Measure	MCLG	MCL	Likely Source of Contamination
<b>Microbiological Contaminants</b>						
Turbidity	N	0.025 100% of monthly samples <0.3	NTU	0	TT	Soil runoff
Total organic carbon	N	<0.1	ppm	NA	TT	Naturally present in the environment

Inorganic Contaminants						
Nitrate	N	0.087	ppm	10	10	Runoff from fertilizer use; leakage from septic tanks, sewage; erosion of natural deposits
Barium	N	0.017	ppm	2	2	Discharge from drilling waste; discharge from metal refineries; erosion of natural deposits
Fluoride	N	<0.08	ppm	4	4	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum plants
Selenium	N	<0.001	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Volatile Organic Contaminants						
Chlorine	N	Annual avg. 1.15 Range 0.8 to 1.7	ppm	4 MRDLG	4 MRDL	Water additive used to control microbes
Haloacetic acids (HAAC5)	N	0.8	ppb	NA	60	By-product of drinking water disinfection
Total trihalomethanes (TTHMs)	N	0.7	ppb	NA	80	By-product of drinking water chlorination

**WE ARE PLEASED TO REPORT THAT CENTRAL HAMPSHIRE PSD, GREEN SPRINGS AND THE CITY OF ROMNEY MET ALL FEDERAL AND STATE WATER STANDARDS FOR THE REPORTING YEAR 2017.**

### Additional Information

All other water test results for the reporting year 2017 were all non-detects.

Turbidity is a measure of the cloudiness in water. We monitor it because it is a good indicator of the effectiveness of our filters.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The **Central Hampshire PSD** is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at

<http://www.epa.gov/safewater/lead>.

This report will not be mailed. A copy will be provided to you upon request at our office during regular business hours.